



DO NOT SCALE FROM THIS DRAWING. USE FIGURED DIMENSIONS IN ALL CASES. VERIFY DIMENSIONS ON SITE AND REPORT ANY DISCREPANCIES TO THE DESIGNERS IMMEDIATELY.
 THIS DRAWING TO BE READ IN CONJUNCTION WITH THE DESIGNERS SPECIFICATION.
 © THIS DRAWING IS COPYRIGHT AND MAY ONLY BE REPRODUCED WITH THE DESIGNERS PERMISSION.


- NOTES:
1. THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL RELEVANT ENGINEERS, ARCHITECTS AND ESB NETWORKS DRAWINGS & SPECIFICATIONS.
 2. ALL DIMENSIONS ARE IN **MILLIMETRES**, UNLESS NOTED OTHERWISE.
 3. DRAWINGS ARE NOT TO BE SCALED.
 4. THE CONTRACTOR SHALL CHECK ALL DIMENSIONS PRIOR TO CONSTRUCTION. ANY DISCREPANCIES TO BE NOTIFIED TO THIS OFFICE IN WRITING IMMEDIATELY. ANY DISCREPANCIES BETWEEN THESE DOCUMENTS SHALL BE BROUGHT TO THE ATTENTION OF THE ENGINEER.
 5. SAND SHALL BE NATURAL UNWASHED SAND IN ACCORDANCE WITH BS 882-1992 (BS EN 12620) COMPLYING WITH GRADING LIMIT C IN TABLE 4 WITH A MAXIMUM THERMAL RESISTIVITY OF 1.0 K.m/WATT AT 0% MOISTURE CONTENT.
 6. ALL MATERIALS AND WORKMANSHIP TO BE IN ACCORDANCE WITH THE NRA SPECIFICATION FOR ROADWORKS.



COMPOUND DETAIL
SCALE NTS



LIGHTING COLUMN & SURROUND DETAILS
SCALE 1:25



TRENCH DETAIL FOR DUCTING
SCALE NTS

PO5	03/10/24	ISSUED FOR APPROVAL	AK	PC
PO4	28/05/24	ISSUED FOR APPROVAL	AK	PC
PO3	22/05/24	ISSUED FOR PLANNING	AK	PC
PO2	01/05/24	ISSUED FOR PLANNING	AK	PC
PO1	20/09/23	ISSUED FOR PLANNING	AK	PC
REV	DATE	DESCRIPTION	BY	APP

PROJECT:
**DERNACART WIND FARM 110KV
 SUBSTATION AND GRID CONNECTION**

TITLE:
COMPOUND DETAILS

CLIENT:
STATKRAFT IRELAND



DRAWN: A.K.	CHECKED: G. McN.	APPROVED: P.C.
PROJECT NUMBER: 23606	DATE: SEPT. '23	SCALE @ A1: AS SHOWN
STATUS DESCRIPTION: FOR APPROVAL		STATUS: S4

DRAWING NUMBER: 23268 - MWP -SS-XX-DR-C-5406	REV: P05
---	-------------